



The City of Oxford
(513) 524-5200
15 S. College Ave.
Oxford, OH 45056

Addendum #1: Q&A as of May 21st, 2026

Q: Is the City open to a system size with a slightly larger or smaller size AC than 30kW-AC?

A: Yes, the City is open to small variations in system sizes if it is more cost-effective.

Q: What type of service does the location have?

A: The Senior Center receives 240 V / single phase. However, the meter could be used for single-phase and three-phase.

Q: What is the square footage of the facility?

A: 7,506 sq ft

Q: Does the City have a preference for panel or inverter-level tracking?

A: The City is not interested in any additional tracking on the system, due to budgetary constraints.

Q: Does the city have a preference between black and silver panels?

A: Yes, the City prefers black panels.

Q: Is the City interested in pursuing the Domestic Content Bonus?

A: The City is interested in utilizing domestic content and pursuing the domestic content bonus if it is cost-effective.